

WOLTMAN WATER METER 50mm – 200mm

100 l/pulse

PULSE REGISTER INSTALLATION GUIDELINES

STEP 1

Remove brass headring security wire.

Loosen headring and remove (being careful to retain sealing rings in the headring).

Remove standard (non-pulse register).



STEP 2

Remove o-ring from metal side of standard register, and transfer to new pulse register.

Insert pulse register into meter.

Replace and tighten headring.

Replace security wire if required.



STEP 3

Insert 'blue' section of reed switch assembly into pulse register receptacle. Note: be sure to align guide groove on reed switch with groove in register to ensure full insertion.

Slide 'black' reed switch cover down over reed switch and lock it onto register.



Installation Recommendation

It is recommended that cable length from Reed Switch to receiving electronics be kept to a minimum to minimise the risk of electrical interference.

Reed Switch Specifications

Maximum Switched Voltage: 48 VDC

Maximum Switched Current: 50mA